



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 826/10/2020-21

Date : 28/10/2020

REPORT OF STACK EMISSION ANALYSIS

Name of company : Gallantt Metal Limited

Survey No. 175/1, Near toll gate,

Village : Samakhyali,

Taluka : Bhachau,


Kutch, Gujarat.

Sr. No.	Particulars	Unit	Stack - 1
01.	Date of sampling	---	11/10/2020
02.	Time of sampling	Hr	10.20
03.	Stack Attached to	---	AFBC Boiler of Power Plant
04.	Air Pollution Control Measures	---	ESP
05.	Stack Height	Meter	90
06.	Stack Diameter	Meter	3.8
07.	Ambient Temperature	Degree Centi.	33
08.	Stack Temperature	Degree Centi.	125
09.	Average Velocity of Flue Gases	M/Sec.	7.8
10.	Isokinetic flow rate for P.M. Sampling	LPM	19
11.	Gaseous Sampling Flow Rate	LPM	2.0
12.	Permissible Limit for P.M.	mg/Nm ³	50
13.	Measured Concentration of P.M.	mg/Nm ³	42.5
14.	Permissible Limit for SO ₂	mg/Nm ³	600
15.	Measured Concentration of SO ₂	mg/Nm ³	88.1
16.	Permissible Limit for NOx	mg/Nm ³	300
17.	Measured Concentration of NOx	mg/Nm ³	86.5

*Permissible limit are as per MoEF&CC Notification S.O.3305(E), dated 07/12/2015.

Instruments used : Ecotech Stack Sampler, Model No. ESS 100

Calibration Done On. : 13/10/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 828/10/2020-21

Date : 28/10/2020

REPORT OF STACK EMISSION ANALYSIS

Name of company : **Gallantt Metal Limited**

Survey No. 175/1, Near toll gate,

Village : Samakhyali,

Taluka : Bhachau,

Kutch, Gujarat.

Test Method : As per IS Standards - 11255_1/2/3/7

Sr. No.	Particulars	Unit	Stack - 3	Stack - 4
1	Date of sampling	---	11/10/2020	11/10/2020
2	Time of sampling	Hr	11.30	12.20
3	Stack Attached to	---	Rotary Kiln - 1, 2	Rotary Kiln - 3
4	Air Pollution Control Measures	---	Recouptur & ESP	Recouptur & ESP
5	Stack Diameter	Meter	1.5	1.5
6	Stack Height	Meter	35	35
7	Stack Temperature	Degree Centi.	123	135
8	Ambient Temperature	Degree Centi.	32	32
9	Average Velocity of Flue Gases	M/Sec.	7.1	7.3
10	Isokinetic flow rate for P.M. Sampling	LPM	16	17
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0
12	Permissible Limit for P.M.	mg/Nm ³	100	100
13	Measured Concentration of P.M.	mg/Nm ³	58.6	73.5
14	Permissible Limit for SO ₂	ppm	100	100
15	Measured Concentration of SO ₂	ppm	72.4	75.2
16	Permissible Limit for Nox	ppm	50	50
17	Measured Concentration of Nox	ppm	26.5	22.6
18.	Permissible Limit for CO*	% (V/V)	1.0%	1.0%
19.	Measured Concentration of CO*	% (V/V)	0.5	0.6

*Permissible limit are as per MoEF&CC Notification G.S.R.414(E), dated 30/05/2008.

Instruments used : Ecotech Stack Sampler, Model No. ESS 100

Calibration Done On. : 13/10/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 829/10/2020-21

Date : 28/10/2020

REPORT OF STACK EMISSION ANALYSIS

Name of company : **Gallantt Metal Limited**

Survey No. 175/1, Near toll gate,

Village : Samakhali,

Taluka : Bhachau,

Kutch, Gujarat.


Test Method : As per IS Standards - 11255 1/2/3/7

Sr. No.	Particulars	Unit	Stack - 5	Stack - 6
1	Date of sampling	---	11/10/2020	11/10/2020
2	Time of sampling	Hr	14.20	15.40
3	Stack Attached to	---	Induction Furnace - 1 & 4	Induction Furnace - 2 & 3
4	Air Pollution Control Measures	---	Cyclone Separator & Wet Scrubber	Cyclone Separator & Wet Scrubber
5	Stack Diameter	Meter	1.5	1.5
6	Stack Height	Meter	48	30
7	Stack Temperature	Degree Centi.	125	130
8	Ambient Temperature	Degree Centi.	34	34
9	Average Velocity of Flue Gases	M/Sec.	7.3	6.8
10	Isokinetic flow rate for P.M. Sampling	LPM	18	17
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0
12	Permissible Limit for P.M.	mg/Nm ³	50	50
13	Measured Concentration of P.M.	mg/Nm ³	34.2	36.4
14	Permissible Limit for SO ₂	ppm	100	100
15	Measured Concentration of SO ₂	ppm	37.2	35.1
16	Permissible Limit for Nox	ppm	50	50
17	Measured Concentration of Nox	ppm	24.8	23.5

*Permissible limit not specified in EC copy as well as in GPCB CC&A

Instruments used : Ecotech Stack Sampler, Model No. ESS 100

Calibration Done On. : 13/10/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 826/10/2020-21

Date : 28/10/2020

REPORT OF FUGITIVE EMISSION MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1,
Near toll gate,
Village : Samakhyali,
Taluka : Bhachau,
Kutch, Gujarat.

Sampling Site: Near raw material handling area

Sr. No.	Particulars	Unit	Location # 1	Location # 2	Location # 3	Location # 4
01.	Location of Sampling	---	Nr. Vagon Trippler	Nr. Sreen Area	Nr. Transfer Point	Nr. Stock Bin area
02.	Date of sampling	---	15/10/2020	15/10/2020	15/10/2020	15/10/2020
03.	Time of sampling	Hr	8.20	8.40	8.45	8.55
04.	Dominant Wind Direction (From)	---	NW to SW	NW to SW	NW to SW	NW to SW
05.	Average Wind Speed	Km/Hr	3 to 18	3 to 18	3 to 18	3 to 18
06.	Average flow rate during sampling	m ³ /minute	1.20	1.20	1.10	1.10
07.	Permissible limit for SPM	µg/m ³	2000	2000	2000	2000
08.	Measured Concentration of SPM	µg/m ³	1723	1645	1785	1832

Instruments Used : Envirotech HVS APM 430 & Ecotech RDS - AAS 217

Calibration done on : 17/06/2020



Royal Environment Auditing & Consultancy Service

Jagat
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 827/10/2020-21

Date : 28/10/2020

REPORT OF FUGITIVE EMISSION MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1,

Near toll gate,

Village : Samakhyali,

Taluka : Bhachau,


Kutch, Gujarat.

Sampling Site: **Crusser area**

Sr.No.	Particulars	Unit	Location # 5	Location # 6	Location # 7
01.	Location of Sampling	---	Nr. Crusser area	Nr. Vibrating screen	Nr. Transfer point
02.	Date of sampling	---	15/10/2020	15/10/2020	15/10/2020
03.	Time of sampling	Hr	9.15	16.20	16.40
04.	Dominant Wind Direction (From)	---	NE	NE	NE
05.	Average Wind Speed	Km/Hr	2 to 16	2 to 16	2 to 16
06.	Average flow rate during sampling	m ³ /minute	1.10	1.20	1.20
07.	Permissible limit for SPM	µg/m ³	2000	2000	2000
08.	Measured Concentration of SPM	µg/m ³	1751	1632	1662

Instruments Used : Envirotech HVS APM 430 & Ecotech RDS - AAS 217

Calibration done on : 17/06/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalsenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 828/10/2020-21

Date : 28/10/2020

REPORT OF FUGITIVE EMISSION MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1,
Near toll gate,
Village : Samakhali,
Taluka : Bhachau,
Kutch, Gujarat.

Sampling Site: Raw material feeder area

Sr. No.	Particulars	Unit	Location # 8	Location # 9	Location # 10
01.	Location of Sampling	---	Nr. Feeder area	Nr. mixing Feeder area	Nr. Transfer point
02.	Date of sampling	---	15/10/2020	15/10/2020	15/10/2020
03.	Time of sampling	Hr	16.40	17.30	17.40
04.	Dominant Wind Direction (From)	---	NW to SW	NW to SW	NW to SW
05.	Average Wind Speed	Km/Hr	2 to 16	2 to 16	2 to 16
06.	Average flow rate during sampling	m ³ /minute	1.20	1.10	1.20
07.	Permissible limit for SPM	µg/m ³	2000	2000	2000
08.	Measured Concentration of SPM	µg/m ³	1358	1750	1720

Instruments Used : Envirotech HVS APM 430 & Ecotech RDS - AAS 217

Calibration done on : 17/06/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 829/10/2020-21

Date : 28/10/2020

REPORT OF FUGITIVE EMISSION MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1,

Near toll gate,

Village : Samakhyali,

Taluka : Bhachau,


Kutch, Gujarat.

Sampling Site: Cooler Discharge Area

Sr. No.	Particulars	Unit	Location # 11	Location # 12
01.	Location of Sampling	---	Nr. Wagon tippler	Nr. Screen area
02.	Date of sampling	---	16/10/2020	16/10/2020
03.	Time of sampling	Hr	8.50	9.00
04.	Dominant Wind Direction (From)	---	NW to SW	NW to SW
05.	Average Wind Speed	Km/Hr	6 to 14	6 to 14
06.	Average flow rate during sampling	m ³ /minute	1.20	1.20
07.	Permissible limit for SPM	µg/m ³	2000	2000
08.	Measured Concentration of SPM	µg/m ³	1753	1568

Instruments Used : Envirotech HVS APM 430 & Ecotech RDS - AAS 217

Calibration done on : 17/06/2020



Royal Environment Auditing & Consultancy Service

Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalsenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 830/10/2020-21

Date : 28/10/2020

REPORT OF FUGITIVE EMISSION MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1,
Near toll gate,
Village : Samakhali,
Taluka : Bhachau,
Kutch, Gujarat.

Sampling Site: Product Processing area

Sr. No.	Particulars	Unit	Location # 13	Location # 14	Location # 15	Location # 16
01.	Location of Sampling	---	Nr. Intermediate stock bin area	Nr. Screening plant	Nr. Magnetic separating plant	Nr. Transfer plant
02.	Date of sampling	---	16/10/2020	16/10/2020	16/10/2020	16/10/2020
03.	Time of sampling	Hr	8.40	8.50	9.10	16.10
04.	Dominant Wind Direction (From)	---	NW to SW	NW to SW	NW to SW	NW to SW
05.	Average Wind Speed	Km/Hr	3 to 16	3 to 16	3 to 16	3 to 16
06.	Average flow rate during sampling	m ³ /minute	1.20	1.20	1.10	1.10
07.	Permissible limit for SPM	µg/m ³	2000	2000	2000	2000
08.	Measured Concentration of SPM	µg/m ³	1524	1754	1658	1484

Instruments Used : Envirotech HVS APM 430 & Ecotech RDS - AAS 217

Calibration done on : 17/06/2020



Royal Environment Auditing & Consultancy Service

Jagdish
Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 831/10/2020-21

Date : 28/10/2020

REPORT OF FUGITIVE EMISSION MONITORING

Name of company : **Gallantt Metal Limited**


Survey No. 175/1,
Near toll gate,
Village : Samakhyali,
Taluka : Bhachau,
Kutch, Gujarat.

Sampling Site: Product Processing area

Sr. No.	Particulars	Unit	Location # 17	Location # 18	Location # 19
01.	Location of Sampling	---	Nr. Oversize discharge area	Nr. Product separation	Bagging area
02.	Date of sampling	---	16/10/2020	16/10/2020	16/10/2020
03.	Time of sampling	Hr	16.25	16.45	17.00
04.	Dominant Wind Direction (From)	---	NW to SW	NW to SW	NW to SW
05.	Average Wind Speed	Km/Hr	3 to 16	3 to 16	3 to 16
06.	Average flow rate during sampling	m ³ /minute	1.20	1.20	1.20
07.	Permissible limit for SPM	µg/m ³	2000	2000	2000
08.	Measured Concentration of SPM	µg/m ³	1575	1532	1510

Instruments Used : Envirotech HVS APM 430 & Ecotech RDS - AAS 217

Calibration done on : 17/06/2020



Royal Environment Auditing & Consultancy Service

Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. : 832/10/2020-21

Date : 28/10/2020

REPORT OF AMBIENT AIR QUALITY MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1, Near toll gate,

Village : Samakhyali,

Taluka : Bhachau,

Kutch, Gujarat.

Sr. No.	Particulars	Unit	Location No. 1	Location No. 2
01.	Location of Sampling	---	Officer Colony	Main Security Gate
02.	Date of sampling	---	15/10/2020	15/10/2020
03.	Time of sampling	Hr	8.20	8.40
04.	Duration of Sampling	Min.	1440	1440
05.	Average Wind Speed	Km/Hr	2 to 14	2 to 14
06.	Average flow rate during sampling	m ³ /Hr	1.1	1.2
07.	Average flow rate for Gas sampling	LPM	0.2	0.2
08.	Permissible Limits of PM 2.5	µg/m ³	60	60
09.	Measured Concentration of PM 2.5	µg/m ³	34	40
10.	Permissible Limits of PM 10	µg/m ³	100	100
11.	Measured Concentration of PM 10	µg/m ³	62	65
14.	Permissible Limits of SO ₂	µg/m ³	80	80
15.	Measured Concentration of SO ₂	µg/m ³	16.2	15.1
16.	Permissible Limits of NO ₂	µg/m ³	80	80
17.	Measured Concentration of NO ₂	µg/m ³	19.8	21.5

Instrument used : 1) Ecotech make (RDS), Model No. APM - 217 BL, Gaseous Sampling Kit No. AAS 190, 2) Ecotech make 2 Nos. PM 2.5

Calibration done on : 15/06/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 833/10/2020-21

Date : 28/10/2020

REPORT OF AMBIENT AIR QUALITY MONITORING

Name of company : **Gallantt Metal Limited**

Survey No. 175/1, Near toll gate,

Village : Samakhali,

Taluka : Bhachau,

Kutch, Gujarat.

Sr. No.	Particulars	Unit	Location No. 3	Location No. 4
01.	Location of Sampling	---	B/h. Kiln 1 & 2	Nr. Furnace Area
02.	Date of sampling	---	16/10/2020	16/10/2020
03.	Time of sampling	Hr	8.50	9.05
04.	Duration of Sampling	Min.	1440	1440
05.	Average Wind Speed	Km/Hr	3 to 18	4 to 18
06.	Average flow rate during sampling	m ³ /Hr	1.1	1.2
07.	Average flow rate for Gas sampling	LPM	0.2	0.2
08.	Permissible Limits of PM 2.5	µg/m ³	60	60
09.	Measured Concentration of PM 2.5	µg/m ³	33	35
10.	Permissible Limits of PM 10	µg/m ³	100	100
11.	Measured Concentration of PM 10	µg/m ³	56	50
14.	Permissible Limits of SO ₂	µg/m ³	80	80
15.	Measured Concentration of SO ₂	µg/m ³	15.5	13.5
16.	Permissible Limits of NO ₂	µg/m ³	80	80
17.	Measured Concentration of NO ₂	µg/m ³	16.7	18.2

Instrument used : 1) Ecotech make (RDS), Model No. APM - 217 BL, Gaseous Sampling Kit No. AAS 190, 2) Ecotech make 2 Nos. PM 2.5

Calibration done on : 15/06/2020





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 834/10/2020-21

Date : 28/10/2020

AMBIENT NOISE LEVEL MEASUREMENT

Name of company : **Gallantt Metal Limited**

Survey No. 175/1,

Near toll gate,

Village : Samakhali,

Taluka : Bhachau,

Kutch, Gujarat.

Sr. No.	Location of Sampling	Noise Level Avg. in dB (A)	
	Date of sampling	10/15/2020	10/15/2020
	Time of sampling	Day Time 6.00 AM - 10.00 PM	Night Time 10.00 PM - 6.00 AM
	Permissible Limits	75.0	70.0
01.	Near Main Gate	57.6	54.3
02.	Rolling Mill Area	71.3	62.8
03.	Induction Furnace	68.4	63.5
04.	Reheating Furnace	72.3	63.7
05.	Rotary Kiln	71.1	64.5
06.	Power Plant	70.2	66.2

Instruments used : Sound level meter, Model : SL - 4030 (Lutron Make)

Range : A - 30 to 80 dB, B-50 to 100 dB, C-80 to 130 dB.

Calibration done on : 12/09/2020



Royal Environment Auditing & Consultancy Service

Analyst



Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 836/10/2020-21

Date : 28/10/2020

REPORT OF DRINKING WATER SAMPLE


Name of company : **Gallantt Metal Limited**

Survey No. 175/1,
Near toll gate,
Village : Samakhali,
Taluka : Bhachau,
Kutch, Gujarat.

Date of sampling : 15/10/2020

Sr. No.	Parameters	Unit	Permissible Limits(*)	Results
01.	pH	pH Units	6.5 to 8.5	7.32
02.	Colour	Pt. Co. Scale	100	Colourless
03.	Total Dissolved Solids	mg/l	2000	185
04.	Total Suspended Solids	mg/l	----	8
05.	Total Solids	mg/l	----	193
06.	Chlorides	mg/l	1000	54
07.	Sulphates	mg/l	400	10
08.	Total Hardness (As CaCO ₃)	mg/l	600	68
09.	Calcium (as Ca)	mg/l	200	12.4
10.	Magnesium (as Mg)	mg/l	100	6.2
11.	Total Alkalinity	mg/l	600	58
12.	Nitrates	mg/l	45	2.2
13.	Flouride	mg/l	1.5	0.06

(*) Permissible Limit in the Absense of Alternate Source as per IS 10500 : 2018, Drinking Water Specification





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 837/10/2020-21

Date : 28/10/2020

WASTE WATER SAMPLE ANALYSIS REPORT

Name of company : **Gallantt Metal Limited**


Survey No. 175/1,
Near toll gate,
Village : Samakhya,
Taluka : Bhachau,
Kutch, Gujarat.

Date of sampling : 15/10/2020

Source of Sample: Waste Water Treatment Plant (ETP Plant)

Sr. No.	Parameters	Unit	GPCB Limits *	Waste Water (ETP Inlet)	Treated Water (ETP Outlet)
1	pH	pH Unit	6.5 to 8.5	7.23	7.58
2	Colour	Pt.co scale	100 Units	30	15
3	Temp.	°C	40	36	34
4	Suspended Solids	Mg/Lit	100	65	23
5	Total Dissolved Solids	Mg/Lit	---	881	482
6	Total Solids	Mg/Lit	---	946	505
7	Oil & Grease	Mg/Lit	10	3.5	0.55
8	Sulphides	Mg/Lit	2	3.2	0.36
9	Phosphate	Mg/Lit	5	6.4	0.8
10	BOD	Mg/Lit	30	73	18
11	COD	Mg/Lit	100	348	44
12	Total Chromium (as Cr)	Mg/Lit	0.2	0.76	N.D.
13	Hexavalent Cr	Mg/Lit	0.1	0.81	N.D.
14	Copper	Mg/Lit	1.0	0.62	0.52
15	Total Iron (as Fe)	Mg/Lit	1.0	3.4	0.62
16	Zinc (as Zn)	Mg/Lit	1.0	0.6	NIL

* GPCB Limits are only applicable to treated waste water (ETP Outlet)





Royal

Environment Auditing & Consultancy Service

303-304, Shivalik-7, B/s. Bal Adalat, Gondal Road, RAJKOT - 360 002.

Ph.: +91 281 2360695 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

TEST REPORT (WATER)

Test Report No : 838/10/2020-21

Date : 28/10/2020

Work Order No : -----

Job Card No : Gallant/20-21/048

Name of company : Gallant Metal Limited

Survey No. 175/1, Near toll gate,
Village : Samakhya,
Taluka : Bhachau,
Kutchh.

Attention : Mr. Manoj Rastogi

Date of Sample Receipt : 16/10/2020

Date & Time of Sampling : 15/10/2020 , 11.00

Lab ID : W/20-21/10/023

Date of Testing : 16th to 21st October 2020

Sample Type : Water

Description of Sample Packing : Plastic Bottle

Type of Sampling : Grab

Quantity of Sample : 1.0 Ltr.

Description : Ground Water

Sample Collected by : Royal Environment

Sampling Method : IS 3025 : Part 1

Location of Sample : Ground Water - Nr. Solid Waste Storage Area

Sr. No.	Parameters	Unit	Acceptable Limits	Permissible Limits as per IS 10500:2018	Results	Test Method
01.	Color	Hazen Units	5	15	Colorless	IS 3025 : Part 44
02.	Odour	---	Agreeable	Agreeable	Odourless	IS 3025 : Part 5
03.	pH Value	---	6.5 - 8.5	No relaxation	7.35	IS 3025 : Part 11
04.	Turbidity	NTU	1	5	5	IS 3025 : Part 10
05.	Total Dissolved Solids	mg/l	500	2000	932	IS 3025 : Part 16
06.	Total Suspended Solids	mg/l	---	---	28	IS 3025 : Part 17
07.	Total hardness (as CaCO ₃)	mg/l	200	600	502	IS 3025 : Part 21
08.	Calcium (as Ca)	mg/l	75	200	118	IS 3025 : Part 40
09.	Magnesium (as Mg)	mg/l	30	100	48	IS 3025 : Part 46
10.	Chloride (as Cl)	mg/l	250	1000	262	IS 3025 : Part 32
11.	Sulphate (as SO ₄)	mg/l	200	400	338	IS 3025 : Part 24
12.	Total alkalinity as (as CaCO ₃)	mg/l	200	600	236	IS 3025 : Part 23
13.	Nitrate (as NO ₃)	mg/l	45	No relaxation	132	IS 3025 : Part 34
14.	Fluoride (as F)	mg/l	1	1.5	0.06	IS 3025 : Part 60
15.	Iron (as Fe)	mg/l	0.3	No relaxation	0.3	IS 3025 : Part 53
16.	Mineral oil	mg/l	0.5	No relaxation	N.D.	IS 3025 : Part 39
17.	Phenolic compounds (as C ₆ H ₅ OH)	mg/l	0.001	0.002	N.D.	IS 3025 : Part 43
18.	Total arsenic (as As)	mg/l	0.01	0.05	Nil	IS 3025 : Part 37
19.	E. Coli	---	Absent	Absent	Absent	APHA
20.	Total Coliform Bacteria	---	Absent	Absent	Absent	APHA

**** This water can't be used as drinking water**

Authorized Signatory

Rajkot

Analyst

* End of Report *

1. This test report shall not be reproduced except in full, without written approval from the Royal Environment Auditing & Consultancy Service
2. The results relate only to the item tested.

Doc. No. F/7.8/03, Issue No. 02, Issue Date : 01-10-18, Ammd No. —, Ammd Date : —

Form No. 37
(Prescribed under Rule 12-B)

Register containing particulars of monitoring of working environment required under Section 7-A (a)(e).

- 1 Name of the Department/Plant : **Gallantt Metal Limited**
- 2 Raw materials, by products and finished products involved in the process. **RSPM**
- 3 Particulars of sampling

Date of sampling : 15/10/2020

Sr. No	Location Operation monitored	Identified Contaminate	Sampling Instrument used	Airborne Contamination			TWA concentration (As given in Second Schedule)	Refrance Method	Number of Workers exposed at the location being monitored	Remarks	Signature person taking samples	Name (in block letters)
				Number of sample	Range	Average	Mg/m ³					
1	Nr. Stone Area	RSPM	Personal Respirable Dust sampler VPDS 203	02	1.3-2.5	1.90	10	Gravimetric	5	---		Mr. MAKVANA JAGDISH
2	Nr. SMS	RSPM		02	1.2-2.6	2.00	10	Gravimetric	3	---		
3	Nr. Power Plant	RSPM		02	1.5-2.8	2.2	10	Gravimetric	3	---		
4	Nr. Kiln - 2 Side	RSPM		02	2.2-3.10	2.65	10	Gravimetric	5	---		
5	Nr. Kiln - 3 Side	RSPM		02	1.9-2.8	2.4	10	Gravimetric	4	---		
6	Nr. Crusher Area	RSPM		02	2.3-3.0	2.65	10	Gravimetric	6	---		
7	Rolling Mill Area	RSPM		02	1.4-3.10	2.25	10	Gravimetric	3	---		

Instrument Used : Vaibhav make Personal Sampler, Model No. VPDS 203
Calibration done on : 13/03/2020



For. Royal Environment Auditing & Consultancy Service


Authorized Sign