



Royal

Environment Auditing & Consultancy Service

Plot No. 19 & 20, B/s. The North Star Nest School, Masoom School Road, Mota Mava, RAJKOT - 360 005.
Ph.: +91 9099919954 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 4126/12/2022-23

Date : 30/12/2022

REPORT OF STACK EMISSION ANALYSIS

Name of company : Gallantt Ispat Limited
Survey No. 175/1, Near toll gate,
Village : Samakhali,
Taluka : Bhachau,
Kutch, Gujarat.

Sr. No.	Particulars	Unit	Stack - 1
01.	Date of sampling	---	19/12/2022
02.	Time of sampling	Hr	09:30
03.	Stack Attached to	---	AFBC & CFBC Boiler of Power Plant
04.	Air Pollution Control Measures	---	ESP
05.	Stack Height	Meter	95
06.	Stack Diameter	Meter	3.8
07.	Ambient Temperature	Degree Centi.	28
08.	Stack Temperature	Degree Centi.	130
09.	Average Velocity of Flue Gases	M/Sec.	7.6
10.	Isokinetic flow rate for P.M. Sampling	LPM	21
11.	Gaseous Sampling Flow Rate	LPM	2.0
12.	Permissible Limit for P.M.	mg/Nm ³	30
13.	Measured Concentration of P.M.	mg/Nm ³	19.2
14.	Permissible Limit for SO ₂	mg/Nm ³	100
15.	Measured Concentration of SO ₂	mg/Nm ³	37
16.	Permissible Limit for NO _x	mg/Nm ³	100
17.	Measured Concentration of NO _x	mg/Nm ³	32.3
18.	Permissible Limit for Hg	mg/Nm ³	0.03
19.	Measured Concentration of Hg	mg/Nm ³	0.019

*Permissible limit are as per MoEF&CC Notification S.O.3305(E), dated 07/12/2015.

Instruments used : Ecotech Stack Sampler, Model No. ESS 100

Calibration Done On. : 27/12/2021

Royal Environment Auditing & Consultancy Service

Ashish
Analyst



Royal

Environment Auditing & Consultancy Service

Plot No. 19 & 20, B/s. The North Star Nest School, Masoom School Road, Mota Mava, RAJKOT - 360 005.
Ph.: +91 9099919954 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Date : 30/12/2022

Ref. No. : 4128/12/2022-23

REPORT OF STACK EMISSION ANALYSIS

Name of company : **Gallantt Ispat Limited**

Survey No. 175/1, Near toll gate,

Village : Samakhyali,

Taluka : Bhachau,

Kutch, Gujarat.

Test Method : As per IS Standards - 11255 1/2/3/7

Sr. No.	Particulars	Unit	Stack - 2	Stack - 3	Stack - 4
1	Date of sampling	---	19/12/2022	19/12/2022	19/12/2022
2	Time of sampling	Hr	10:00	10:45	11:30
3	Stack Attached to	---	Rotary Kiln - 1 & 2	Rotary Kiln - 3 & 4	Rotary Kiln - 5 (New) (350 TPD)
4	Air Pollution Control Measures	---	ESP	ESP	ESP
5	Stack Diameter	Meter	1.5	1.5	1.5
6	Stack Height	Meter	35	35	48
7	Stack Temperature	Degree Centi.	124	115	128
8	Ambient Temperature	Degree Centi.	28	28	29
9	Average Velocity of Flue Gases	M/Sec.	6.8	7.0	6.9
10	Isokinetic flow rate for P.M. Sampling	LPM	20	19	20
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0	2.0
12	Permissible Limit for P.M.	mg/Nm ³	100	100	100
13	Measured Concentration of P.M.	mg/Nm ³	40	41.2	38
14	Permissible Limit for SO ₂	ppm	100	100	100
15	Measured Concentration of SO ₂	ppm	31.0	33.0	30.0
16	Permissible Limit for Nox	ppm	50	50	50
17	Measured Concentration of Nox	ppm	23.0	25.0	22.0

*Permissible limit are as per MoEF&CC Notification G.S.R.414(E), dated 30/05/2008.

Instruments used : Ecotech Stack Sampler, Model No. ESS 100

Calibration Done On. : 27/12/2021

Royal Environment Auditing & Consultancy Service



Ashish
Analyst



Royal

Environment Auditing & Consultancy Service

Plot No. 19 & 20, B/s. The North Star Nest School, Masoom School Road, Mota Mava, RAJKOT - 360 005.
Ph.: +91 9099919954 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 4129/12/2022-23

Date : 30/12/2022

REPORT OF STACK EMISSION ANALYSIS

Name of company : **Gallantt Ispat Limited**

Survey No. 175/1, Near toll gate,
Village : Samakhali,
Taluka : Bhachau,
Kutch, Gujarat.

Test Method : As per IS Standards - 11255 1/2/3/7


Sr. No.	Particulars	Unit	Stack - 5	Stack - 6	Stack - 7
1	Date of sampling	---	19/12/2022	19/12/2022	19/12/2022
2	Time of sampling	Hr	12:15	14:00	14:50
3	Stack Attached to	---	Induction Furnace - 1 & 2	Induction Furnace - 3 & 4	Induction Furnace - 5 & 6
4	Air Pollution Control Measures	---	Bag Filter with Spark Trapper	Bag Filter with Spark Trapper	Bag Filter with Spark Trapper
5	Stack Diameter	Meter	1.5	1.5	1.5
6	Stack Height	Meter	48	48	48
7	Stack Temperature	Degree Centi.	128	125	123
8	Ambient Temperature	Degree Centi.	29	30	30
9	Average Velocity of Flue Gases	M/Sec.	7	7.1	7.3
10	Isokinetic flow rate for P.M. Sampli	LPM	20	21	19
11	Gaseous Sampling Flow Rate	LPM	2.0	2.0	2.0
12	Permissible Limit for P.M.	mg/Nm ³	50	50	50
13	Measured Concentration of P.M.	mg/Nm ³	23.1	28	25.4
14	Permissible Limit for SO ₂	ppm	100	100	100
15	Measured Concentration of SO ₂	ppm	36.4	31.1	34
16	Permissible Limit for NO _x	ppm	50	50	50
17	Measured Concentration of NO _x	ppm	22.1	21.6	20

*Permissible limit as per GPCB CC&A

Instruments used : Ecotech Stack Sampler, Model No. ESS 100

Calibration Done On : 27/12/2021

Royal Environment Auditing & Consultancy Service



Ashish
Analyst